




January 11, 2018

Carl Posewitz
Paradigm Architecture
125 ½ East Main
Missoula, MT.

Re: Gym Parapet Wall Collapse
Linderman School
Polson, MT.

Carl:

This is an addendum to the letter written on January 8th regarding the collapse of the gym parapet wall and locker room roof of the above noted building. DCI recommends demoing the locker room roof from the west end to the music building located on the east end. No demo is required for the music room. The south brick locker room wall may also be demoed along this same area (no demo beyond the music room). Temporary sheathing should be placed on the music room interior wall (spanning N/S) where roof and wall demo terminate to enclose it from the outside.



Sincerely,
DCI ENGINEERS

Chris Schlegel, PE
Principal

Mark Bradford, PE

